
Separate Amplifier Proximity Sensor with Adjustment Potentiometer

E2C/E2C-H

Separate Amplifier Sensor with Sensitivity Adjustment

- · Compact design with smaller Sensor Head.
- \bullet Heat-resistance model available for application between -10 and $200^\circ C.$





Ordering Information

Sensors [Refer to *Dimensions* on page 18.] Standard Models

	Sensor					Amplifier U	nits	
Appeara	nce	Stable sensing area *	Model	Combination	Model			Self-diag- nostic output
	3.5 dia.	0.8 (1.8) mm	E2C-CR8A 3M		E2C-GE4A	DC/		
	3.8 dia.	0.8 (1.8) mm	E2C-CR8B 3M	_		(NPN)		
	M5	1 (2) mm	E2C-X1A 3M E2C-GF4A	E2C-GF4A	DC/ (PNP)			
Shielded	5.4 dia.	1 (2) mm	E2C-C1A 3M			DC/		
	M8	1.5 (3) mm	E2C-X1R5A 3M		E2C-JC4AP 2M *	(NPN)	Yes	Yes
	M12	2 (5) mm	E2C-X2A 3M		E2C-JC4A 2M	DC/	Yes	
	M18	5 (10) mm	E2C-X5A 3M	1.1		(NPN)		
	M30	10 (18) mm	E2C-X10A 3M		E2C-AM4A			
Unshielded	40 dia.	20 (50) mm	E2C-C20MA 3M		E2C-AK4A	AC		

*1. Values in parentheses are for the maximum sensing distances at 23°C.

* Self-diagnostic output, timer, and DIN Track mounting.

Heat-resistant Model

		Sensor	Combination	Amplifier Unit	
Appear	ance	Stable sensing area	Model	-Combination	Model
Objetee	M8	1.5 mm	E2C-X1R5AH 3M	- I	E2C-JC4CH 2M
Shielded	M12	2 mm	E2C-X2AH 3M		E2C-JC4DH 2M
	M18	5 mm	E2C-X5AH 3M		E2C-JC4EH 2M

Note: Characteristics will change if the cable length changes. Do not cut or extend the cable.

Accessories (Order Separately)

Mounting Brackets A Mounting Bracket is not provided with the Sensor. Order a Mounting Bracket separately if required. [Refer to Dimension on page 21.]

Name	Model	Applicable Sensors	Remarks
Mounting Brackets	Y92E-F3R5	E2C-CR8A, for 3.5 dia.	
Mounting Brackets	Y92E-F5R4	E2C-C1A, for 5.4 dia.	

Connection Sockets A Socket is not provided with the Amplifier Unit. Order a Socket separately if required. [Refer to Dimension on page 21.]

Name	Model	Applicable Amplifier Unit	Remarks
Front Connection Sockets	PYFZ-08	E2C-GE4A E2C-GF4A	Hold-down Clips (Order Separately) PYC-A1 Sold as a set.
	P2CF-08	E2C-AM4A	
	P2CF-11	E2C-AK4A	
	P3G-08	E2C-AM4A	
Back Connection Sockets	P3GA-11	E2C-AK4A	
Back Connection Sockets	PY08	E2C-GE4A E2C-GF4A	

Nut Sets A Nut Set is included with the Sensor. Order a Nut Set when required, e.g., if you lose the nuts.

Model	Applicable Sensors	Applicable Sensor diameter	Set contents
Y92E-NWM05	E2C-X1A	M5	Clamping nuts (brass with nickel plating): 2 Toothed washer (iron with zinc plating): 2

Adapters An Adapter is not provided with the Amplifier Unit. Order an Adapter separately if required. [Refer to Dimension on page 21.]

Name	Model	Applicable Amplifier Unit	Remarks
	Y92F-30		
Embedded Adapters	Y92F-70	E2C-AM4A/-AK4A	
	Y92F-71		

For details on *Mounting Brackets, Protective Covers, and Sputter Protective Covers*, refer to Accessories on Y92.

Ratings and Specifications

Standard Models

Sensors

ltem	Model	E2C-CR8A/ -CR8B	E2C-X1A/ -C1A	E2C-X1R5A	E2C-X2A	E2C-X5A	E2C-X10A	E2C-C20MA
Sensing	distance (at 23°C)	1.8 mm	2 mm	3 mm	5 mm	10 mm	18 mm	50 mm
Stable sensing	Ambient temperature	0 to 0.8 mm	0 to 1 mm	0 to 1.5 mm	0 to 2 mm	0 to 5 mm	0 to 10 mm	0 to 20 mm
area	At 0 to 40°C	0 to 1.2 mm	0 to 1.5 mm	0 to 2 mm	0 to 2.5 mm	0 to 7 mm	0 to 15 mm	0 to 28 mm
Different	ial travel	Refer to Ratings	s and Specificati	ons on page 4 for	Amplifier Unit sp	ecifications.	1	L
Detectab	le object	Ferrous metal (The sensing dist	ance decreases v	with non-ferrous r	netal. Refer to <i>Er</i>	ngineering Data o	on page 7.)
Standaro ject	l sensing ob-	Iron, $5 \times 5 \times 1$ n	nm	Iron, $8 \times 8 \times$ 1 mm	$\begin{array}{c} \text{Iron, } 12 \times 12 \times \\ 1 \text{ mm} \end{array}$	Iron, $18 \times 18 \times 11$ mm	Iron, $30 \times 30 \times 1$ mm	Iron, 50 \times 50 \times 1 mm
Respons frequenc		1 kHz		800 Hz		350 Hz	100 Hz	50 Hz
Ambient temperature range Operating/Storage: -25 to 70°C (with no icing or condensation)								
Ambient humidity		ange Operating/Storage: 35% to 95% (with no condensation)						
Tempera influence		15% max. of se	nsing distance a	t 23°C in the tem	perature range of	–25 to 70°C		
Vibratior	n resistance	Destruction: 10	to 55 Hz, 1.5-mr	n double amplitue	de for 2 hours ea	ch in X and Y dire	ections	
Shock re	esistance	Destruction: 500	0 m/s² 3 times ea	ach in X and Y dir	rections			
Degree o	of protection	IEC 60529 IP67	′, in-house stand	ards: oil-resistan	t			
Connact	ion method *2	Pre-wired Models						
Connect		High-frequency	coaxial cable (S	tandard cable ler	igth: 3 m)		0 to 10 mm 0 to 20 mm 0 to 15 mm 0 to 28 mm Engineering Data on page 7.) Iron, 30 × 30 × Iron, 30 × 30 × Iron, 50 × 50 1 mm 1 mm 100 Hz 50 Hz	
Weight (packed	state)	Approx. 40 g	Approx. 45 g	Approx. 50 g	Approx. 60 g	Approx. 140 g	Approx. 270 g	Approx. 300 g
	Case	Stainless steel	Brass					L
	Sensing surface	ABS resin						
Materi- als	Cable	Vinyl chloride (F	PVC)				Polyethylene (PE)	
413	Clamping nut		Brass, nickel-pl	ated (except E20	C-C1A)		1	
	Toothed washer		Iron, zinc-plate	d (except E2C-C	IA)			
Accesso	ries		1					

*1. The minimum value when using the solid-state control output on the Amplifier Unit. Measurement conditions are as follows: standard sensing object, a distance of twice the standard sensing object, and a set distance of half the sensing distance.
 *2. Refer to 6 for cable lengths when combining Amplifier Units and Sensors. The characteristic impedance of the high-frequency coaxial cable is 50 Ω.

Amplifier Units

Item	Model	E2C-GE4A	E2C-GF4A	E2C-JC4A E2C-JC4AP	E2C-AM4A	E2C-AK4A	
	pply volt- ating volt- e)	12 to 24 VDC (10 to 30 VD	C), ripple (p-p): 10% max. *1			100 to 240 VAC (90 to 264 VAC) 50/60 Hz	
Current consump	tion	25 mA max.		45 mA max.	50 mA max.	55 mA max.	
Sensing o adjustme	distance nt range *2	20% min. of rated sensing ometer	distance with 4-turn potenti-	20% to 100% of rated sens	sing distance with 4-turn pote	entiometer	
Differenti adjustme		Differential travel fixed (109	% max. of sensing distance)	1	1% to 5% of rated sensing	distance	
Re- sponse	Solid- state	(Refer to the response freq	uency of the Proximity Sens	or.)	1		
time	Relay		-		1	20 ms max.	
Control outputs	Solid- state Load resistance: 4.7 kΩ, 100 mA max. Load 100 mA max. Load 100 mA max. ontrol (30 VDC max.) (30 VDC max.) <t< td=""><td>PNP Load resistance: 4.7 kΩ, 100 mA max. (30 VDC max.) (Residual voltage: 1.5 V max.)</td><td>NPN Open-collector output 100 mA max. (30 VDC max.) (Residual voltage: 0.7 V max.) (E2C-JC4AP: 1 V max.)</td><td>NPN/PNP output Open-collector output 200 mA max. (30 VDC max.) (Residual voltage: 1.5 V max.)</td><td>Transistor/photocoupler 50 mA max. (40 VDC max.) (Residual voltage: 2 V max.)</td></t<>		PNP Load resistance: 4.7 kΩ, 100 mA max. (30 VDC max.) (Residual voltage: 1.5 V max.)	NPN Open-collector output 100 mA max. (30 VDC max.) (Residual voltage: 0.7 V max.) (E2C-JC4AP: 1 V max.)	NPN/PNP output Open-collector output 200 mA max. (30 VDC max.) (Residual voltage: 1.5 V max.)	Transistor/photocoupler 50 mA max. (40 VDC max.) (Residual voltage: 2 V max.)	
	Relay		-			Relay output, SPDT 2 A at 250 VAC, cosǫ = 1 (resistive load) *3	
Indicators					Detection indicator (red) (C Stability indicator (green) (
Operatior	n mode	Changed with NO/NC swite	ch.	1	1		
Self-diagı output	nostic			(E2C-JC4AP only) Output transistor turns ON when Sensor open circuit or unstable sensing is de- tected; solid-state NPN open-collector 50 mA max. (30 VDC max.) (Residual voltage: 1 V max.)	-		
Timer fun	oction	-		OFF-delay: 40 ±10 ms	-		
Cable len compens between S Amplifier	ation Sensor and	-		(E2C-JC4AP only) 3 m/5 m, terminals Short-plate switching Shorted: 1 to 3 m Open: 3 to 5 m	Mode switched with 4-posi	tion switch.	
Ambient temperati	ure range	Operating/storage: -10 to 5	55°C (with no icing or conder	nsation)			
Ambient humidity	range	Operating/Storage: 35% to	85% (E2C-JC4AP: 35% to 9	95%) (with no condensation)			
Temperat influence		10% max. of sensing distar	nce at 23°C in the temperatu	re range of −10 to 55°C			
Voltage ir	nfluence			age in the rated voltage $\pm 20^{\circ}$ age in the rated voltage $\pm 10^{\circ}$			
Insulatior resistanc		50 MΩ min. (at 500 VDC) b	etween current-carrying par	ts and case			
	strength	DC Models: 1,000 VAC, 50 AC Models: 1,500 VAC. 50	/60 Hz for 1 min between cu /60 Hz for 1 min between cu	rrent-carrying parts and case rrent-carrying parts and case	e e		
Vibration	resistance		mm double amplitude for 2	Destruction: 10 to 55 Hz, 1.5-mm double amplitude for 2 hours each in X, Y, and Z directions	bestruction: 10 to 25 Hz, 2-mm double amplitude hours each in X, Y, and Z directions		
		1					

*1. A full-wave rectification power supply of 24 VDC ±10% (average value) can be used (except for the E2C-GE4□).
*2. The sensing distance range required to maintain performed is given for using the Amplifier Unit in combination with the Sensor.
*3. Internal relay: G2R-14 DC 12V

Model	E2C-GE4A	E2C-GF4A	E2C-JC4A E2C-JC4AP	E2C-AM4A	E2C-AK4A	
Shock resistance	Destruction: 100 m/s ² 3 time	es each in X, Y, and Z direct	tions			
Life expectancy						
Connection method	Terminal block		Pre-wired Models (Standard cable length: 2 m)	Terminal block		
Weight (packed state) *4	Approx. 20 g		E2C-JC4A: Approx. 50 g E2C-JC4AP: Approx 80 g	Approx. 140 g	Approx. 250 g	
Accessories	Instruction manual		Caution labels, Mounting Bracket (E2C-JC4A: M3 × 15 Phillips mounting screw), instruction manual	Instruction manual		

*4. The weight of the Connection Socket is not included.

Heat-resistant Models

Sensors

ltem	Model	E2C-X1R5AH	E2C-X2AH	E2C-X5AH		
Detect	able object		e sensing distance , refer to <i>Engineerii</i>			
Standa object	rd sensing	Iron, 8 × 8 × 1 mm	Iron, $12 \times 12 \times 11$ mm	Iron, $18 \times 18 \times 11$ mm		
Stable area	sensing	0 to 1.5 mm	0 to 2 mm	0 to 5 mm		
Differe	ntial travel	0.04 mm max.		0.1 mm max.		
Respo freque		300 Hz				
Ambie ture ra	nt tempera- nge	Operating/Storage densation)	e: –10 to 200°C (wi	th no icing or con-		
Ambie humidi	nt ity range	Operating/Storage: 35% to 95% (with no condensation)				
Tempe influen		±0.2%/°C	0.2%/°C			
Vibrati resista		Destruction: 10 to 2 hours each in X	55 Hz, 1.5-mm do , Y, and Z direction	uble amplitude for s		
Shock	resistance	Destruction: 500 n tions	n/s² 3 times each in	X, Y, and Z direc-		
Degree protect		IEC 60529 IP60 *2	2			
Conne od	ction meth-		(Cable length: 3 m gh-frequency coaxia			
Weight (packe	t d state)	Approx. 50 g	Approx. 60 g	Approx. 140 g		
	Case	Brass				
	Sensing surface	PEEK (polyether ether ketone)				
Mate-	Cable	Fluorine resin				
rials	Clamping nut	Brass, nickel-plate	ed			
	Toothed washer	Iron, zinc-plated				

Note: Ratings and characteristic are given for 50% of the stable sensing area. *1. Measurement conditions are as follows: standard sensing object, a distance of twice the standard sensing object, and a set distance of half the sensing

distance. *2. Do not operate the Sensor in areas exposed to water vapor because the

enclosure is not waterproof.

Amplifier Units

Item	Model	E2C-JC4CH	E2C-JC4DH	E2C-JC4EH		
Power voltage (operat range)		12 to 24 VDC (10 to 30 VDC), ripple (p-p): 10% max.				
Curren tion	t consump-	45 mA max.				
	g distance nent range	20% to 100% of ra 4-turn potentiome	ated sensing distan ter	се		
Con- trol	Load current	NPN open collected	or, 100 mA max. (3	0 VDC max.)		
out- puts	Residual voltage	0.8 V max.				
Indicat	ors	Detection indicato	r (red)			
Operat	ion mode	Changed with NO	/NC switch.			
Cable I compe	ength nsation	Switched betweer	and 5 m.			
Ambier ture ra	nt tempera- nge	Operating/storage: -10 to 55°C (with no icing or con- densation)				
Ambier humidi	nt ty range	Operating/storage: 35% to 85% (with no condensation)				
Tempe influen		±0.08%/°C				
Voltage	e influence	$\pm 2\%$ max. of sensing distance at rated voltage in the rated voltage $\pm 20\%$ range				
Insulat resista		50 $M\Omega$ min. (at 500 VDC) between current-carrying parts and case				
Dielect strengt		1,000 VAC, 50/60 ing parts and case	Hz for 1 min betwe	en current-carry-		
Vibrati resista			55 Hz, 1.5-mm dou Y, and Z direction			
Shock	resistance	Destruction: 100 r tions	n/s² 3 times each in	X, Y, and Z direc-		
Degree protect		IEC 60529 IP20				
Conne method		Pre-wired Models (Cable length: 2 m)				
Weight state)	(packed	Approx. 80 g				
Access	ories	Caution labels, Mounting Bracket, instruction manual				
*1. A full		ation power supply	of 24 VDC ±10% (a	average value) can		

*2. The sensing distance range required to maintain performed is given for using the Amplifier Unit in combination with the Sensor.

Cable Lengths for Sensor-Amplifier Unit Combinations

Standard Models

Sensor Amplifier Units	E2C-CR8A	E2C-CR8B	E2C-X1A	E2C-C1A	E2C- X1R5A	E2C-X2A	E2C-X5A	E2C-X10A	E2C- C20MA
E2C-GE4A		Pa	estricted to 3	m					
E2C-GF4A		r.e	sincled to 3						
E2C-JC4AP	1 to 3 m: Short cable length terminals * 3 to 5 m: Open cable length terminals *								
E2C-JC4A		Restricted to 3 m.							
E2C-AM4A		0 to 5 m					0 to	10 m	
E2C-AK4A	S	et cable length	n switch to de	sired position	. *	Set cable	e length switc	h to desired p	osition. *

Note: The standard cable length is 3 m. Models with 5-m or 10-m are manufactured upon order. * Refer to page 14 for the operation of cable length switching.

Heat-resistant Models


Sensor Amplifier Units	E2C-X1R5AH	E2C-X2AH	E2C-X5AH		
E2C-JC4CH			•		
E2C-JC4DH	Set 3 m/5 m cable length switch to desired position.				
E2C-JC4EH					


Note: The standard cable length is 3 m. Models with 5-m are manufactured upon order.

Self-diagnostic Function

The self-diagnostic output transistor will turn ON in the following cases. (The output will turn ON for any of these conditions individually.) (1) Sensor open circuit: Transistor will turn ON the instance there is an open circuit for the Sensor (including the cable).

Sensor Open Circuit






Note: When the E2C-X2A Sensor is used, 93% is 96% and 107% is 104%.
 The self-diagnostic output may turn ON if the sensing objects moves a low speed. In actual application, include an ON-delay timer circuit or other suitable measure.

- (2) Detection: The output will turn ON if a sensing object is within 93% to 100% of the sensing distance continuously for 0.3 s or longer (e.g., for sensing object position offset).
- (3) No detection: The output will turn ON if a sensing object is within 100% to 107% of the sensing distance continuously for 0.3 s or longer (e.g., when background is influencing detection).

Indicators


• The detection indicator lights when a sensing object approaches the sensing distance to indicate that a sensing object has been detected.

• The stability indicator lights when the sensing object approaches within 93% of the sensing distance or moves away from 107% of the sensing distance to indicate a stable sensing or non-sensing condition.




Engineering Data (Reference Value)


Sensing Area E2C-CR8




E2C-X1A/-C1A




E2C-X1R5A




E2C-X2A




E2C-X5A




E2C-X1R5AH + E2C-JC4CH



E2C-X10A




E2C-X2AH + E2C-JC4DH




-Y Sensing distance (variable): 4 to 20 mm


E2C-C20MA




E2C-X5AH + E2C-JC4EH




Influence of Sensing Object Size and Material E2C-CR8




E2C-X1A/-C1A (mm)




E2C-X5A




E2C-X1R5AH + E2C-JC4CH




E2C-X1R5A




E2C-X2A




E2C-C20MA




E2C-X5AH + E2C-JC4EH



E2C-X10A



E2C-X2AH + E2C-JC4DH







I/O Circuit Diagrams


Output con- figuration	E2C-GE4A *	E2C-JC4A, E2C-JC4CH, E2C-JC4DH, E2C-JC4EH
NPN output	 * A voltage output can be used if the NO/NC switch on the E2C-GE4A is set to NC, but an approximately 60-ms pulse will be generated when the power supply is turned ON. An initial reset will thus be required. If the E2C-GF4A (model for PNP output) is used, the initial pulse will not occur. 	Proximity Sensor main circuit 100 mA 2.2 Ω Black Output 47 V Blue 0 V
	E2C-J	IC4AP
NPN output Self-diag- nosis Func- tion	Detection indicator (Red) Proximity Sensor main circuit	Brown 12 to 24 VDC Load Black 100 mA 2.2Ω 3.9Ω Z_0
	E2C-	GF4A
PNP Output	Proximity Sensor main circuit 4.7 kΩ max.	13 12 to 24 VDC 13 47 V 22 20 0 V 0 V
	E2C-/	AM4A
Both NPN and PNP outputs	Proximity Sensor main circuit 200 mA max.	47V 2.2 Ω Output 1 (PNP) 2.2 Ω Output 2 (NPN) 47V 7 0 V
	E2C-	AK4A
Transistor/ photocou- pler Relay out- put	Proximity Sensor main circuit	6 Output (+) 6 Output (-) Note: Terminals 1, 2, and 3 are the relay contact output (SPDT).


Connections between Amplifier Unit and Sensor



Load Connections










The E2C-AK4A supports relay and transistor/photocoupler outputs, and the E2C-AM4A supports both NPN and PNP open-collector output. They can be connected to a wide variety of load types and power polarities.

Nomenclature and Timing Charts

Amplifier Units







Set this switch to the proper setting depending on whether the standard cable length is being used or the cable has been cut shorter.

Amplifier Unit Switch Settings

Applicable Sensors	Cable length	0 to 1 m	1 to 2 m	2 to 3 m	3 to 4 m	4 to 5 m	5 to 6 m	6 to 7 m	7 to 8 m	8 to 9 m	9 to 10 m
E2C-CR8A E2C-CR8B E2C-X1A E2C-C1A E2C-X1R5A		A B C D	A B C D	A B C D	A B C D	A B C D					
E2C-X2A E2C-X5A E2C-X10A E2C-C20MA		A B C D									

Note: 1. Mutual Interference Prevention: When mounting Sensors with the same diameter and cable length in parallel, set the DIP switch to modes that differ by 1 m in cable length. Specifications, however, may not be sufficiently met, so always check operation before actual application. This method cannot be used for the E2C-C20MA.

2. When using the E2C-CR5B + E2C-AM4A (or AK4A), set all the pins on the Amplifier Unit DIP switch to the left.

Safety Precautions

Refer to Warranty and Limitations of Liability.

<u> WARNING</u>

This product is not designed or rated for ensuring safety of persons either directly or indirectly. Do not use it for such purposes.




Precautions for Correct Use

Do not use the Encoder under ambient conditions that exceed the ratings.

Design

Influence of Surrounding Metal

When mounting the Sensor within a metal panel, ensure that the clearances given in the following table are maintained. Failure to maintain these distances may cause deterioration in the performance of the Sensor.



Influence of Surrounding Metal

tal (Unit: mm)

Model	Distance	I	d	D	m
E2C-CR8			(3.5)		2.4
E2C-X1A			(5)		3
E2C-C1A			(5.4)		5
E2C-X1R5A	A(H)	0	(8)	0	4.5
E2C-X2A(H)		(12)		6
E2C-X5A(H)		(18)		15
E2C-X10A			(30)		30
E2C-C20MA	4	25	120	40	60

Note: Values in parentheses for diameter d are the outer diameters of Shielded Models.

Mutual Interference

When installing Sensors face-to-face or side-by-side, ensure that the minimum distances given in the following table are maintained. Mutual interference can be prevented by using the cable length compensation switch, but doing so will also change coil characteristics. Specifications such as temperature specifications and sensing distance, may not be sufficiently met, so always check operation before actual application.

This method cannot be used for the E2C-G□4A, E2C-JC4A, E2C-C20MA.



Mutual Interference (Unit: mm)

Model	Distance	Α	В
E2C-CR8			
E2C-X1A		20	15
E2C-C1A		20	15
E2C-X1R5A	(H)		
E2C-X2A(H)		30	20
E2C-X5A(H)		50	35
E2C-X10A		100	70
E2C-C20MA		300	200

Note: The above values are for a differential travel setting of 5%.

Mounting

• Do not use excessive force when tightening the nuts on the E2C-X and E2C-C20MA. A washer must be used with the nut.




Model	Torque
E2C-X1A	0.98 N∙m
E2C-X1R5A(H)	2.0 N·m
E2C-X2A(H)	5.9 N∙m
E2C-X5A(H)	15 N·m
E2C-X10A	39 N∙m
E2C-C20MA	15 N·m

Note: The above leeways in tighten torque assume that a toothed washer is being used.

Mounting Unthreaded Cylindrical Models

When using a set screw, tighten it to a torque of 0.2 $N{\cdot}m$ max.



Y92E-F3R5 Mounting Bracket (for 3.5 dia.) (Order Separately)



The Y92E-F5R4 (for 5.4 dia.) is also sold separately.


Mounting

Mounting the Amplifier Unit

E2C-JC4A


Lengthwise Mounting

- (1)Secure the Mounting Bracket with the enclosed M3 screws.
- (2)Loosen the M2.6 cover screw and remove the cover.
- (3)Slide the protrusion on the Amplifier Unit into the hole on the Mounting Bracket.
- (4)Using the M3 mounting screw inside the Amplifier Unit, secure the Amplifier Unit to the mounting base.
- (5)Secure the cover to the case.



Mounting to the Side

- (1)Loosen the M2.6 cover screw and remove the cover. Loosen the M2.6 cover screw and remove the cover, and remove the M3 screw.
- (2)Attached the enclosed M3 screw to the cover and secure the cover to the case.
- (3)Secure the Amplifier Unit with M3 screws from the side. You must provide these screws.




enclosed caution label over the adjustment holes to prevent adjustment mistakes.



E2C-A 4A Using P2CF-11


Using P2CF-11, P2CF-08

When aligning the Amplifier Unit vertically with the Socket, consider the space required for the hooks and allow a leeway of about 20 mm above and below the Amplifier Unit.




Mounting Embedded in a Panel

(1)When using the Y92F-30 Embedded Mounting Adapter, insert the Amplifier Unit into a square hold in the panel, attach the Adapter from the back and press in to reduce the gap with the panel. Then secure the Adapter with the screws.




(2)When using the Y92F-70 or Y92F-71 Embedded Mounting Adapter, just press the Amplifier into a square hole in the panel. If the panel coating is too thick and the hooks do not lock in place, spread the hooks from the back by pushing in the directions of the arrows.




Removing the Amplifier Unit

• When the Amplifier Unit is mounted using the Y92F-30, loosen the screws on the adapter, spread the hooks at the top and bottom, and remove the Adapter.



- Using Y92F-70, Y92F-71
- Press in on the hooks with your thumb and forefinger and press forward on the Amplifier Unit.



• Wiring

Self-diagnostic Output

When not using the self-diagnostic output, connect the orange wire to 0 V or cut it and wrap it with insulation tape so that it does not come into contact with other terminals.

Miscellaneous


The sensor does not have a water-resistant structure. Do not use it where it would be subjected to water or water vapor.

Dimensions


(Unit: mm) Tolerance class IT16 applies to dimensions in this data sheet unless otherwise specified.


Main Units






Model	F (mm)	Model	F (mm)	Model	F (mm)
E2C-CR8A	3.7-dia. ^{+0.3}	E2C-X1A	5.4-dia. ^{+0.5}	E2C-X5A	18.5-dia. ^{+0.5}
E2C-CR8B	4.0-dia. ^{+0.3}	E2C-X1R5A	8.5-dia. ^{+0.5}	E2C-X10A	30.5-dia. ^{+0.5}
E2C-C1A	5.7-dia. +0.3	E2C-X2A	12.5-dia. +0.5	E2C-C20MA	18.5-dia. ^{+0.5}






*1. After completing adjustments, attach the caution label to prevent adjustment mistakes
*2. Not required when mounting to DIN Track.
*3. 4-dia. vinyl-insulated round cable with 3 conductors (Conductor cross section: 0.2 mm², Insulator diameter: 1.2 mm), Standard length: 2 m
The cable can be extended up to 200 m (separate metal conduit).

Accessories (Order Separately) Mounting Bracket




31.2 max

Back Connection Sockets



Embedded Mounting Adapter (for E2C-AK4A/E2C-AM4A Amplifier Unit)

Y92F-30



Terms and Conditions Agreement

Read and understand this catalog.

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments.

Warranties.

(a) Exclusive Warranty. Omron's exclusive warranty is that the Products will be free from defects in materials and workmanship for a period of twelve months from the date of sale by Omron (or such other period expressed in writing by Omron). Omron disclaims all other warranties, express or implied.

(b) Limitations. OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE

PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE.

Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or otherwise of any intellectual property right. (c) Buyer Remedy. Omron's sole obligation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repay or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsible for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were properly handled, stored, installed and maintained and not subject to contamination, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Companies shall not be liable for the suitability or unsuitability or the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warranty.

See http://www.omron.com/global/ or contact your Omron representative for published information.

Limitation on Liability; Etc.

OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY.

Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted.

Suitability of Use.

Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT(S) IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

Programmable Products.

Omron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof.

Performance Data.

Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application requirements. Actual performance is subject to the Omron's Warranty and Limitations of Liability.

Change in Specifications.

Product specifications and accessories may be changed at any time based on improvements and other reasons. It is our practice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the Product may be changed without any notice. When in doubt, special part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron's representative at any time to confirm actual specifications of purchased Product.

Errors and Omissions. Information presented by Omron Companies has been checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical or proofreading errors or omissions.

In the interest of product improvement, specifications are subject to change without notice.

OMRON Corporation Industrial Automation Company