OMRON

形**ZFX-SC150**

スマートセンサ 形 ZFX-C□□用 センサヘッド

取扱説明書

このたびは、本製品をお買い上げいただきまして、まことにありがとうございます。 ご使用に際しては、次の内容をお守りください。

- ・電気の知識を有する専門家がお取り扱いください。
- ・この取扱説明書をよくお読みになり、十分にご理解のうえ、正しくご使用ください。
- ・この取扱説明書はいつでも参照できるよう大切に保管してください。



安全上の要点

以下に示すような項目は安全を確保する上で必要なことですので必ず守ってください。 1. 設置環境について

- ・引火性、爆発性ガスの環境では使用しないでください。
- ・操作や保守の安全を確保するため、高電圧機器や動力機器から離して設置してくださ
- ・取付けにおいて、ねじの締め付けは確実に行ってください。
- 2. 雷源および配線について
- ・高圧線、動力線と当製品の配線は別配線としてください。同一配線あるいは同一ダクトにす ると誘導を受け、誤動作あるいは破損の原因になることがあります。

- ・本製品を分解したり、修理、改造したりしないでください。
- ・廃棄するときは、産業廃棄物として処理してください。
- ・異臭がする、本体が非常に熱くなる、煙が出るなどの異常が起こった場合、すぐに使用を 中止し、電源を切った状態で当社支店・営業所までご相談ください。

使用上の注意

製品が動作不能、誤動作、または性能・機器への悪影響を防ぐため、 以下のことを守ってください。

1.設置場所について 次のような場所には設置しないでください。

- ・周囲温度が定格の範囲を越える場所
- ・温度変化が急激な場所(結露する場所)
- ・相対湿度が 35 ~ 85%RH の範囲を超える場所 ・腐食性ガス、可燃性ガスがある場所
- ・塵埃、塩分、鉄粉がある場所
- ・振動や衝撃が直接加わる場所
- ・強い外乱光(レーザ光、アーク溶接光、紫外光など)があたる場所
- ・直射日光があたる場所や暖房器具のそば
- ・水・油・化学薬品の飛沫がある場所
- ・強磁界、強電界がある場所

2.電源および接続、配線について

- ・センサヘッドの着脱は、必ず電源を切った状態で行ってください。電源 ON のまま行う と故障の原因になります。
- ・センサヘッドとアンプユニットは、取扱説明書で指定した組合せで使用してください。

3.光軸、検出範囲について

光軸中心はセンサヘッドごとにばらつくことがありますので、取付けるときは必ずアンプ ユニットの液晶モニタで画像の中心と検出範囲を確認してください。


- ・通気膜をはがしたり、先の尖ったものでつついたりしないでください。
- 保護構造を満足できなくなるおそれがあります。
- ・通気膜はふさがないでください。センサヘッド前面のパネルが曇るおそれがあります。
- ・センサヘッドやアンプユニットの清掃には、シンナー、アルコール、ベンジン、アセトン、灯油 類は使用しないでください。
- ・センサヘッド前面のパネルに、大きなゴミやホコリが付いた場合は、ブロアブラシ(カメラ レンズ用)で吹き飛ばしてください。呼気で吹き飛ばすことは避けてください。
- ・小さなゴミやほこりは、柔らかい布で丁寧にふきとってください。強くふくことは避けてくだ さい。キズがつくと、誤検出の原因になります。

6.設置に関するご注意

取付けねじは、規定のトルクで締め付けてください。

推奨締付けトルク M4:1.2N·m, 1/4"-20UNC:2.6N·m

■各部の名称と機能




(1)照明部

- LED照明部です。 (2) 受光部
- 画像を取込みます。 (3) コネクタ
- アンプユニットに接続します。
- (4)ピント調整ボリューム
- 画像のピントを調整をするときに使用します。
- 前面パネルの曇りを防止します。


■フェライトコアの装着

センサヘッドの本体側およびコネクタ側にフェライトコア(付属品)を装着してください。



■設置距離

次のグラフは検出範囲と設置距離の関係を表したものです。センサヘッドの形式ごとに値 は異なりますので、形式を十分ご確認の上、グラフをご覧ください。




■設置手順


(1)光学図表から読取った設置距離にセンサヘッドを設置します。 (2)ピント調整ボリュームを左右に回してピントを合わせます




ピント調整ボリュームは多回転ボリュームになってい ますが、ピントが一番近い側(右回転)では回転が 止まります。故障の原因となりますので、無理にボ リュームを回さないでください。(ピントが一番遠い側 (左回転)では空回りします。)



■外形寸法図







(単位:mm)

■定格/性能

項目	形ZFX-SC150	形ZFX-SC150W	形ZFX-SC150R
	(超広視野タイプ)	(超広視野タイプ)	(超広視野タイプ)
設置距離(L)	115mm~227mm(可変)		
検出範囲(H×V)	89×89mm~148×148mm(可変)		
検出範囲と 設置距離の関係	設置距離 (L)		
検出範囲	227mm 115mm 148mm 148mm (H)		
ワーク照明点灯方式	パルス点灯		
ワーク照明用光源	白色発光ダイオード×72個		
オプション照明I/F	なし		
撮像素子	全画素読出し方式インターライン転送型 1/3インチCCD(カラー)		
シャッタ機能	シャッタ時間:1/170~1/20000s		
電源電圧	DC15V、DC48V(アンプユニットより供給)		
消費電流	約350mA[15V:約150mA、48V:約200mA]		
耐電圧	AC1000V 50Hz /60Hz 1分間		
振動(耐久)	10~150Hz 片振幅0.35mm X /Y /Z 方向各8分10回		
衝撃(耐久)	150m /s ² 6方向(上下、左右、前後)各3回		
周囲温度	動作時:0~+40℃ 保存時:−20~+65℃(ただし氷結、結露しないこと)		
周囲湿度	動作時・保存時:各35~85%RH (ただし、結露しないこと)		
周囲雰囲気	腐食性ガスのないこと		
接続方式	コード引き出しタイプ コード引き出しタイプ		コード引き出しタイプ
	(標準コード2m)		(耐屈曲コード2m)
保護構造	IEC60529 規格IP65	IEC60529 規格IP67	IEC60529 規格IP65
材質	ケース: ABS		
質量	約600g(コード含む)		
付属品	フェライトコア2個、取扱説明書(本紙)		

ご使用に際してのご承諾事項

- ①安全を確保する目的で直接的または間接的に人体を検出する用途に、本製品を使用し ないでください。同用途には、当社センサカタログに掲載している安全センサをご使用く ②下記用途に使用される場合、当社営業担当者までご相談のうえ仕様書などによりご確
- 認いただくとともに、定格・性能に対し余裕を持った使い方や、万一故障があっても危険 を最小にする安全回路などの安全対策を講じてください。 a)屋外の用途、潜在的な化学的汚染あるいは電気的妨害を被る用途

またはカタログ、取扱説明書等に記載のない条件や環境での使用

b)原子力制御設備、焼却設備、鉄道·航空·車両設備、医用機械、娯楽機械、 安全装置、および行政機関や個別業界の規制に従う設備

c)人命や財産に危険が及びうるシステム・機械・装置

d)ガス、水道、電気の供給システムや24時間連続運転システムなどの 高い信頼性が必要な設備

e)その他、上記 a) ~ d) に準ずる、高度な安全性が必要とされる用途

*上記は適合用途の条件の一部です。当社のベスト、総合カタログ・データシート等最新版 のカタログ、マニュアルに記載の保証・免責事項の内容をよく読んでご使用ください。

オムロン株式会社 インダストリアルオートメーションビジネスカンパニー

カスタマサポートセンタ 0120-919-066

電話 055-982-5015 (通話料がかかります)

〔技術のお問い合わせ時間〕

■営業時間:8:00~21:00

■営業日:365日

■上記フリーコール以外のセンシング機器の技術窓口:

電話 055-982-5002 (通話料がかかります)

〔営業のお問い合わせ時間〕

- ■営業時間:9:00~12:00/13:00~17:30 (土・日・祝祭日は休業)
- ■営業日:土・日・祝祭日/春期・夏期・年末年始休暇を除く
- ●FAXによるお問い合わせは下記をご利用ください。 カスタマサポートセンタ お客様相談室 FAX 055-982-5051
- ●その他のお問い合わせ先 納期・価格・修理・サンプル・仕様書は貴社のお取引先、 または貴社担当オムロン営業員にご相談ください。

OMRON

Model ZFX-SC150

Smart Sensor For Model ZFX-C Sensor head unit

INSTRUCTION SHEET

Thank you for selecting OMRON product. This sheet primarily describes precautions required in installing and operating the product.

Before operating the product, read the sheet thoroughly to acquire sufficient knowledge of the product. For your convenience, keep the sheet at your disposal.

TRACEABILITY INFORMATION:

Representative in EU: Omron Europe B.V. Wegalaan 67-69 2132 JD Hoofddorp, The Netherlands

Omron Corporation,

Shiokoji Horikawa, Shimogyo-ku, Kyoto 600-8530 JAPAN

3-2 Narutani, Nakayama-cho,

Ayabe-shi, Kyoto 623-0105 JAPAN

© OMRON Corporation 2007-2009 All Rights Reserved.

PRECAUTIONS FOR SAFE USE

This product meets CISPR11 class A . The intended use of this product is in an

Please observe the following precautions for safe use of the products.

(1) Installation Environment

- · Do not use the product in environments where it can be exposed to inflammable / explosive gas.
- To secure the safety of operation and maintenance, do not install the product close to high-voltage devices and power devices.
- During installation, make sure that screws are tightened firmly.
- (2) Power Supply and Wiring
- High-voltage lines and power lines must be wired separately from this product. Wiring them together or placing them in the same duct may cause induction, resulting in malfunction or damage.

- · Do not attempt to dismantle, repair, or modify the product.
- · Dispose of this product as industrial waste.
- If abnormal odors, heating, or smoke occurs, stop using the Smart Sensor immediately, turn OFF the power, and consult with your OMRON representative.

PRECAUTIONS FOR CORRECT USE

Please observe the following precautions to prevent failure to operate, malfunctions, or undesirable effects on product performance.

(1) Installation Site

Do not install the product in locations subjected to the following conditions.

- · Ambient temperature outside the rating
- · Rapid temperature fluctuations (causing condensation)
- · Relative humidity outside the range of 35 to 85% · Presence of corrosive or flammable gases
- · Presence of dust, salt, or iron particles
- · Direct vibration or shock
- · Reflection of intense light (such as other laser beams, electric arc welding machines or ultraviolet rays)
- Direct sunlight or near heaters
- · Water, oil, or chemical fumes or spray
- Strong magnetic or electric field
- (2) Power Supply and Wiring
 - Before connecting/disconnecting the Sensor Head, make sure that the Smart Sensor is turned OFF. The Smart Sensor may break down if the Sensor Head is connected or disconnected while the power is ON.
 - Use only combinations of Sensor Heads and Sensor Controllers specified in this
- (3) Optical Axis and Detection Range

The center of the optical axis sometimes differs according to each Sensor Head. During installation, be sure to check the center of the image and the detection range on the LCD monitor of the Amplifier Unit.

- (4) Ventilation Film
 - · Do not peel off or probe the ventilation film with a sharp-pointed object.
 - If you so, the specifications of the protective structure may no longer be satisfied.
 - · Do not block the ventilation film. Doing so might cause the front panel to be
 - (5) Maintenance and Inspection
 - · Do not use thinner, benzene, acetone or kerosene to clean the Sensor Head and
 - · If large dust particles adhere to the front Panel of the Sensor Head, use a blower brush (used to clean camera lenses) to blow them off. Do not blow off the dust particles with your mouth.
 - To remove smaller dust particles, wipe gently with a soft cloth.
 - Do not use excessive force to wipe off dust particles. Scratches on the front Panel may cause errors.
 - (6) Installation Precautions


Tighter mounting screws at the torque specified.

Recommended screw tightening torque

M4:1.2N·m.

1/4"-20UNC:2.6N·m

■Part Names and Functions




- (2) Receiver part This section captures the
- (3) Connector
- This connector is connected to the Amplifier Unit.
- (4) Focus adjustment control
 - This control is used for adjusting the focus of the image.
- (5) Ventilation film

This film prevents the front panel from condensation.

■ Attaching the ferrite core


Attach the ferrite core (provided with the Smart Sensor) to the case side and the



■Installation distance

The following graphs show the relationship between detection range and setting distance for each model of Sensor Head.

Values differ according to each model of Sensor Head, so fully check the model before using these graphs.



■Installation procedure

■ Specifications

Object lighting method | Pulse lighting

Setting distance (L)

Relation between setting

Object light source

Sensing element

Power supply voltage

Current consumption

Ambient temperature

Ambient humidity

Connection method

Degree of protection

Materials

Accessories

Weight


Dielectric strength

distance and detection range

Detection range (H V)

- (1) Install the Sensor Head at the installation distance obtained in the above graphs.
- (2) Turn the focus adjustment control to the left and right to adjust the focus.

Before tuning the focus adjustment control slightly to the right, make sure that the guide mark is not at the lower limit position. The focus adjustment control is a multi-turn



ZFX-SC150

115 to 227 mm

(Ultra-wide View)

89×89 mm to 148×148 mn

Seventy two white LEDs

1.000 VAC, 50/60 Hz for 1 min

/3-inch interline color CCD (reading all pixels)

Electronic shutter, shutter time: 1/170 to 1/20,000s

15 VDC, 48 VDC (Supplied from Amplifier Unit.)

Vibration resistance (destruction) 10 to 150 Hz, 0.35-mm single amplitude, 10 times each in X, Y, and Z directions for 8 min

Shock resistance (destruction) 150 m/s², three times each in six directions (up/down, left/right, forward/backward)

Approx. 350 mA[15VDC:Approx. 150 mA, 48VDC:Approx. 200 mA]

Operating and storage: 35% to 85% (with no condensation)

Prewired, Standard cable

length: 2 m

IEC60529 IP65

Approx. 600 g (including cord)

Ferrite core (2), Instruction sheet

Operating: 0 to 40 °C, Storage: -20 to 65 °C (with no icing or condensation)

IEC60529 IP67

Not available


Ambient atmosphere Must be free of corrosive gas.

Case: ABS

The control turns idle even after the upper limit position (left turn). Do not exert unnecessary force to turn the control at the upper or lower limit positions as this might damage the control.

ZFX-SC150W

(Ultra-wide View)



ZFX-SC150R


(Ultra-wide View)

Prewired, Crooked-proof cable

IEC60529 IP65

ength: 2 m

Dimensions



Suitability for Use

THE PRODUCTS CONTAINED IN THIS SHEET ARE NOT SAFETY RATED. THEY ARE NOT DESIGNED OR RATED FOR ENSURING SAFETY OF PERSONS, AND SHOULD NOT BE RELIED UPON AS A SAFETY COMPONENT OR PROTECTIVE DEVICE FOR SUCH PURPOSES. Please refer to separate catalogs for OMRON's safety rated products.

OMRON shall not be responsible for conformity with any standards, codes, or regulations that apply to the combination of the products in the customer's application or use of the product.

Take all necessary steps to determine the suitability of the product for the systems, machines, and equipment with which it will be used. Know and observe all prohibitions of use applicable to this product.

NEVER USE THE PRODUCTS FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

See also Product catalog for Warranty and Limitation of Liability.

OMRON EUROPE B.V. Sensor Business Unit Carl-Benz Str.4, D-71154 Nufringen Germany Phone:49-7032-811-0 Fax: 49-7032-811-199 NORTH AMERICA
OMRON ELECTRONICS LLC One Commerce Drive Schaumburg,IL 60173-5302 U.S.A. Phone:1-847-843-7900 Fax:1-847-843-7787

© OCT, 2009

ASIA-PACIFIC OMRON ASIA PACIFIC PTE. LTD. No. 438A Alexandra Road #05-05-08(Lobby 2), Alexandra Technopark, Singapore 119967 Phone: 65-6835-3011 Fax:65-6835-2711 CHINA OMRON(CHINA) CO., LTD. OMRON(CHINA) CO., LID. Room 2211, Bank of China Tower, 200 Yin Cheng Zhong Road, PuDong New Area, Shanghai, 200120, China Phone: 86-21-5037-2222 Fax:86-21-5037-2200 **OMRON Corporation**